

AMENDMENT NO. 2 APRIL 2011
TO
IS 14930 (PART 1) : 2001 CONDUIT SYSTEMS FOR
ELECTRICAL AND COMMUNICATION INSTALLATION

PART 1 GENERAL REQUIREMENTS

(Page 3, clause 6.2.1, Table 2, col heading 2) — Substitute 'Temperature not More than' for 'Temperature not Less than'.

(Page 4, clause 6.4.1) — Substitute the following for the existing matter:

'With protection in accordance with IS 12063 to IP6X.'

(Page 4, clause 6.4.2) — Substitute the following for the existing matter:

'With protection in accordance with IS 12063 to IPX7.'

(Page 6, clause 10.3.2, para 3) — Substitute the words 'The mass of the hammer and the fall height' for 'The hammer and the fall height'.

(Page 7, Table 5, col heading 4) — Substitute 'Tolerance ± 1 percent' for 'Tolerance +1 percent'.

(Page 11, clause 12.1.2.4, para 3, line 5) — Substitute 'there is no evidence of burning or charring within 50 mm of lower extremity of upper clamp and also within 50 mm of the extremity of lower clamp' for 'there is no evidence of burning or charring within 50 mm of the lower extremity of the upper and also within 50 mm of the upper extremity of lower clamp'.

(Page 14, clause 14.2.2.3, para 2) — Substitute 'having a specific gravity of 1.186 kg/l at $27 \pm 2^\circ\text{C}$ ' for 'having a specific gravity of 1.186 kg at $27 \pm 2^\circ\text{C}$ '.