

AMENDMENT NO. 3 AUGUST 2011
TO
IS 14930 (PART 1) : 2001 CONDUIT SYSTEMS FOR
ELECTRICAL AND COMMUNICATION INSTALLATION*

PART 1 GENERAL REQUIREMENTS

(*Page 13, clause 14.1, para 1*) — Substitute the following for the existing:

‘Conduit system when assembled in accordance with the manufacturer’s instructions shall have adequate resistance to external influences with a minimum requirement of IP 67.’

* Title changed vide Amendment No. 1 issued in May 2002.

(ETD 14)

Reprography Unit, BIS, New Delhi, India