

**AMENDMENT NO. 2 FEBRUARY 2007
TO
IS 7098 (PART 3) : 1993 CROSS-LINKED
POLYETHYLENE INSULATED THERMOPLASTIC
SHEATHED CABLES — SPECIFICATION**

**PART 3 FOR WORKING VOLTAGES FROM 66 kV UP TO
AND INCLUDING 220 kV**

(Page 1, clause 4.1) — Substitute the following for the existing clause:

'The conductor shall be composed of plain copper or aluminium wires complying with IS 8130 : 1984 '

(Page 9, clause 20.16.2) — Substitute '10%' for '15%' in the last line.

(Page 10, clause 20.18) — Insert the following new section after clause 20.18

SECTION 5 IDENTIFICATION, PACKING AND MARKING

21 IDENTIFICATION

21.1 Manufacturer's Identification — The manufacturer shall be identified throughout the *length* of cable by manufacturer's name or trade-mark and the voltage grade and year of manufacture indented, printed or embossed or by means of a tape bearing this information. The indentation, printing or embossing shall be done only on the outer sheath.

For manufacturer's name, if none of these methods is employed or if the purchaser so desires, colour identification threads in accordance with a scheme to be approved by the Bureau of Indian Standards shall be employed.

21.2 Cable Code — The following code shall be used for designating the cable:

Amend No. 2 to IS 7098 (Part 3) : 1993

<i>Sl No</i>	<i>Constituent</i>	<i>Code Letter</i>
i)	Aluminium conductor	A
ii)	XLPE insulation	2 x
iii)	Copper screen	C
iv)	Non-magnetic round wire armour	Wa
v)	Lead alloy sheath	Ly
vi)	Aluminium sheath	A
vii)	PVC outer sheath	Y
viii)	Polyethylene outer sheath	2Y

NOTE — No code letter for conductor is required when the conductor material is copper

22 PACKING AND MARKING

22.1 The cable shall be wound on a drum (see IS 10418 1982¹⁾) and packed. The ends of the cable shall be sealed by means of non-hygroscopic sealing material

22.2 The cable shall carry the following information either stenciled on the drum or contained in a label attached to it

- a) Reference to this Indian Standard, for example, see IS 7098 (Part 3),
- b) Manufacturer's name or trade-mark,
- c) Type of cable and voltage grade,
- d) Number of cores,
- e) Nominal cross-sectional area of conductor,
- f) Cable code,
- g) Length of cable on the drum,
- h) Number of lengths on the drum (if more than one);
- j) Direction of rotation of drum (by means of an arrow),
- k) Gross mass;
- m) Country of manufacture, and
- n) Year of manufacture.

Amend No. 2 to IS 7098 (Part 3) : 1993

22.2.1 The cable (drum or label) may also be marked with BIS Standard Mark

NOTE — The use of the Standard Mark is governed by the provisions of Bureau of Indian Standards Act, 1986 and the Rules and Regulations made thereunder. The details of conditions under which the licence for the use of the Standard Mark may be granted to manufacturers or producers may be obtained from the Bureau of Indian Standards.

(ET 9)

Reprography Unit, BIS, New Delhi, India