

AMENDMENT NO. 4 MARCH 2013
TO
IS 7098 (PART 3) : 1993 CROSS-LINKED POLYETHYLENE
INSULATED THERMOPLASTIC SHEATHED CABLES
PART 3 FOR WORKING VOLTAGES FROM 66 kV
UP TO AND INCLUDING 220 kV

(Page 7, clause 19.1.2) — Insert new clause after **19.1.2**:

‘**19.1.2.1** During electrical type testing, if the damage or failure of accessories of cable sample occurs it may be repaired or replaced and the testing shall be continued from the point of break.’

(Page 7, clause 20.1) — Delete the clause and renumber the subsequent clauses.

(Page 7, clause 20.17) — Substitute the following for the existing clause:

‘**20.17** The cable shall with stand without any failure the power frequency AC voltage of 2.5 times the rated voltage for 30 min between conductor and metallic screen at room temperature.’