

**AMENDMENT NO. 2 MARCH 2002
TO
IS 7181 : 1986 SPECIFICATION FOR HORIZONTALLY
CAST IRON DOUBLE FLANGED PIPES FOR WATER,
GAS AND SEWAGE**

(*First Revision*)

(*Page 10, clause 9.1.4, line 3*) — Insert 'for 5 minutes' after the word
'65°C'

(*Page 10, clause 9.1.4*) — Insert the following new clause after 9.1.4:

**'9.1.4.1 Coating test shall be conducted on a sample piece cut from the pipe
having a sample area not less than 10 sq. cm.'**

(MTD 6)

Reprography Unit, BIS, New Delhi, India