

**AMENDMENT NO. 3 JUNE 2010
TO
IS 7181 : 1986 SPECIFICATION FOR HORIZONTALLY
CAST IRON DOUBLE FLANGED PIPES FOR WATER,
GAS AND SEWAGE**

(First Revision)

(Page 5, clause 6.3) — Substitute the following for the existing:

‘Testing may preferably be carried out on uncoated pipes.’

(Page 5, clause 7.3, line 1) — Delete ‘uncoated’.

(MTD 6)

Reprography Unit, BIS, New Delhi, India