

AMENDMENT NO. 2 AUGUST 2019
TO
IS 16444 (PART 1) : 2015 a.c. STATIC DIRECT CONNECTED
WATTHOUR SMART METER CLASS 1 AND 2 —
SPECIFICATION

(Page 5, clause 7.1) — Insert the following para at the end of clause :

‘Category UC1 is applicable to smart meters rated at maximum current upto 100A.’

[Page 6, clause 10.2 (see also Amendment No. 1)] — Substitute the following for the existing clause :

‘10.2 Number of Samples and Criteria for Conformity

Type test shall be made on minimum one or more specimens (1st Set) selected by the manufacturer and test sequence shall be as given in Table 1. Each specimen shall comply with all the tests given in Table 1. In case of one test specimen failing to comply in any respect, further same number(s) of specimen(s) (equivalent to 1st set) shall be taken, all of which shall comply with requirements of standard given in Table 1.

In addition, one additional sample shall comply with load switch requirement of UC1 category and another sample shall comply with data exchange protocol requirement of this standard. For UC2 and UC3 category of meters, the number of samples for load switch requirement shall be as per Annexure G of 15884.

For acceptance test, recommended sampling plan and the criteria for acceptance of the lot are given in relevant Annex of IS 13779.’