

AMENDMENT NO. 1 NOVEMBER 2019
TO
IS 16534 : 2017 CHLORINATED POLYVINYL CHLORIDE
(CPVC) PIPE FITTINGS FOR AUTOMATIC SPRINKLER
FIRE EXTINGUISHING SYSTEM — SPECIFICATION

(Page 2, clause 6.2.3, line 5) — Substitute ‘1 450 kg/m³’ for ‘1 500 kg/m³’.

(Page 3, clause 8.5, line 2) — Substitute ‘1 450 kg/m³’ for ‘1 500 kg/m³’.

(Page 3, clause 9.1.1) — Substitute the following for the existing clause:

‘9.1.1 Short Term

When subjected to internal hydrostatic pressure test in accordance with the procedure given in Annex B, the representative fitting sample shall withstand for 1 min without rupture, separation or leakage, an internal hydrostatic pressure of five times the rated pressure at 65°C. The test shall be conducted at room temperature.’

(Page 5, Annex A) — Substitute the following for the existing entry for IS 4905:

<i>IS No.</i>	<i>Title</i>
4905 : 2015	Random sampling and randomization procedures (<i>first revision</i>)