

AMENDMENT NO. 1 JANUARY 2025
TO
IS 16700 : 2023 CRITERIA FOR STRUCTURAL SAFETY OF TALL
CONCRETE BUILDINGS
(First Revision)

(Page 16, clause **10.2**, para 2) — Substitute the following for the existing:

where

- ‘ Z = seismic zone factor [as defined in IS 1893 (Part 1)];
- x = height of point of attachment of the NSE above top;
- a_p = component amplification factor (*see* Table 10);
- I_p = importance factor of the NSE (*see* Table 9);
- W_p = weight of the NSE;
- h = overall height of the building; and
- R_p = component response modification factor (*see* Table 10).’

[Page 16, Table 10, col (3), heading] — Substitute ‘ a_p ’ for ‘ p ’.

[Page 16, Table 10, col (4), heading] — Substitute ‘ R_p ’ for ‘ p ’.

[Page 18, Table 10, SI No. (ii) (h) (1)] — Substitute the following for the existing:

‘SI No.	NSE	a_p	R_p
(1)	(2)	(3)	(4)
h)	General electrical:		
	1) Distributed systems (bus ducts, conduit, cable tray)	2.5	5.0

(CED 38)

Price Group 1
Publication, BIS, New Delhi