

AMENDMENT NO. 1 MAY 2026
TO
IS 1391 (PART 2) : 2023 ROOM AIR CONDITIONERS — SPECIFICATION
PART 2 SPLIT AIR CONDITIONERS
(Fourth Revision)

(Page 4, clause 5.3.1) — Substitute the following for the existing:

‘5.3.1 The refrigerant pipes and fittings shall pass the following:

- a) Withstand 3 times the design pressure of the refrigeration circuit of air conditioner for at least 1 minute as defined in **7.3.1** of IS 11329; and
- b) Drift expanding test as per **8.3** of IS 10773.’

(MED 03)

Price Group 1
Publication, BIS, New Delhi