

AMENDMENT NO. 4 OCTOBER 1991
TO
IS 1445 : 1977 SPECIFICATION FOR PORCELAIN
INSULATORS FOR OVERHEAD POWER LINES
WITH A NOMINAL VOLTAGE UP TO AND
INCLUDING 1 000 V
(*Second Revision*)

(*Page 14, clause 8.8.2, first sentence*) — Substitute the following for the existing sentence:

'The complete test shall comprise five transfers; hot to cold, cold to hot, hot to cold, cold to hot, and hot to cold.'

(ETDC 6)