

AMENDMENT NO. 5 JANUARY 1993
TO
IS 1445 : 1977 SPECIFICATION FOR PORCELAIN
INSULATORS FOR OVERHEAD POWER LINES
WITH A NOMINAL VOLTAGE UP TO AND
INCLUDING 1 000 V

(*Second Revision*)

(*Page 21, Table 3*) — Substitute the following for the existing table:

**'TABLE 3 SAMPLE SIZE, ACCEPTANCE AND THE
REJECTION NUMBERS**

(*Clause B-1.1*)

LOT SIZE	FIRST SAMPLE SIZE	SECOND SAMPLE SIZE	ACCEPTANCE NUMBER	FIRST REJECTION NUMBER	SECOND REJECTION NUMBER
(1)	(2)	(3)	(4)	(5)	(6)
Up to 500	8	8	0	2	2
501 „ 1 000	13	13	0	3	4
1 001 „ 3 000	20	20	1	4	5
3 001 „ 10 000	32	32	2	5	7
10 001 „ 35 000	50	50	3	7	9
35 001 and above	80	80	5	9	13

(*Page 21, clause B-2*) — Substitute the following for the existing clause:

'B-2 CRITERIA FOR CONFORMITY

B-2.1 The number of insulators selected at random in accordance with col 1 and 2 of Table 3 shall be subjected to all the acceptance tests. An insulator failing to meet any of the requirements for acceptance tests shall be termed as defective. The lot shall be considered as conforming to the requirements of acceptance tests if the number of defectives found in the first sample is less than or equal to the corresponding acceptance number. The lot shall be rejected if the number of defectives is greater than or equal to the corresponding first rejection number (see col 5 of Table 3). If the number of defectives is in between the acceptance number and first rejection number, then a second sample of same size shall be selected from the lot at random and subjected to all the acceptance tests. The lot shall be considered as conforming to the requirements of acceptance tests, if the combined number of defectives in both the samples is less than the second rejection number (see col 6 of Table 3); otherwise not.'

(**ETD 06**)