

**IS:1537-1976 SPECIFICATION FOR VERTICALLY CAST IRON
PRESSURE PIPES FOR WATER, GAS AND SEWAGE**

(First Revision)

AMENDMENT NO. 1 JULY 1977

Alterations

***(Page 4, clause 3.3, line 3) - Substitute
'210 HB' for '210-B'.***

***(Page 10, Table 6, col 1) - Substitute '100' for
'110'.***

AMENDMENT NO. 2 OCTOBER 1978

Alteration

***(Page 14, clause 9.1.2) - Substitute the
following for the existing clause:***

***'9.1.2 The pipes of the heavier mass than the
maximum shall be accepted, provided they comply in
every other respect with the requirements of this
standard.'***

AMENDMENT NO. 3 MARCH 1980

Addenda

***(Page 8, Table 4) - Add the following new note
at the end:***

***'NOTE - The dimensions α , r and s generally do
not affect the interchangeability and are for
guidance only.'***