

**IS:1537-1976 SPECIFICATION FOR VERTICALLY CAST IRON
PRESSURE PIPES FOR WATER, GAS AND SEWAGE**

(First Revision)

AMENDMENT NO. 1 JULY 1977

Alterations

***(Page 4, clause 3.3, line 3) - Substitute
'210 HB' for '210-B'.***

***(Page 10, Table 6, col 1) - Substitute '100' for
'110'.***

AMENDMENT NO. 2 OCTOBER 1978

Alteration

***(Page 14, clause 9.1.2) - Substitute the
following for the existing clause:***

***'9.1.2 The pipes of the heavier mass than the
maximum shall be accepted, provided they comply in
every other respect with the requirements of this
standard.'***

AMENDMENT NO. 3 MARCH 1980

Addenda

***(Page 8, Table 4) - Add the following new note
at the end:***

***'NOTE - The dimensions α , r and s generally do
not affect the interchangeability and are for
guidance only.'***

(Para 14, clause 8.4) - Add the following new clauses under 8.4:

"8.5 Tolerances for the various dimensions of flanges not specified above shall be as follows:

<i>Description</i>	<i>Size, DN</i> mm	<i>Tolerance</i> mm
<i>D</i> (as cast)	Up to 250	+3.0 -1.0
	Above 250	+5.0 -1.5
<i>C</i>	Up to 250	+1.0 -1.5
	Above 250	+1.5 -1.5
<i>d</i>	Up to 300	+2 -0
	Above 300	+3 -0

8.6 Tolerances for dimensions other than those specified above shall be as given in IS:5519-1979 'Deviations for untoleranced dimensions of grey iron castings (first revision)'."

AMENDMENT NO. 4 MARCH 1983

Alteration

[Page 16, clause 11.1(e)] - Delete.

(SMDC 9)