

AMENDMENT NO. 4 DECEMBER 2008
TO
IS 1554 (PART 1) : 1988 SPECIFICATION FOR
PVC INSULATED (HEAVY DUTY) ELECTRIC CABLES
PART 1 FOR WORKING VOLTAGES UP TO AND
INCLUDING 1 100 V

(*Third Revision*)

[Page 12, clause 16.10 (see also Amendment No. 1)] — Substitute 'The measured value of Temperature Index shall be 250°C at 21 percent of oxygen' for 'The measured value of Temperature Index shall be 21 at a Temperature of 250°C'.

(ET 09)