

AMENDMENT NO. 1 MAY 1994
TO
IS 1554 (Part 2) : 1988 SPECIFICATION FOR PVC
INSULATED (HEAVY DUTY) ELECTRIC CABLES
PART 2 FOR WORKING VOLTAGES FROM 3.3 kV UP TO AND
INCLUDING 1 100 kV

(Second Revision)

(Page 1, clause 0.7) — Substitute the following for the existing clause:

‘0.7 A special category of cables with improved fire performance has been included in this standard. Classification of such cables is given in Appendix A.’

(Page 2, clause 1.3) — Insert the following new clause 1.4 after 1.3:

‘1.4 This standard also covers cables with improved fire performance, categories C1 and C2, as given in Appendix A. For such cables additional requirements have been included wherever necessary (*see 8.2, 18.1.3, 18.2.2 and 20.2.1*).

NOTE — Normal cables to this standard can be classified as meeting the requirements of category 01.’

[Page 3, clause 7.1 (b)] — Substitute ‘formed wires’ for ‘strip’.

(Page 3, clause 7.2) — Substitute the following for the first sentence:

‘The galvanized steel wire/formed wires/tapes shall comply with the requirements of IS 3975 : 1988, except that the provisions of 3.3.1 and 3.3.2 shall not apply.’

(Page 3, clause 8.1) — Insert the following new clause 8.2 after 8.1:

‘8.2 For cables with improved fire performance, the outer sheath shall, in addition, meet the requirement of tests applicable for the required category (*18.1.3 and 18.2.2*).’

(Page 5, clause 17.3.2, line 3) — Substitute ‘Table 4’ for ‘Table 5’.

(Page 6, clause 18.1.2.1) — Insert the following new clause 18.1.3 after 18.1.2.1:

‘18.1.3 The following shall constitute additional type tests for cables with improved fire performance as per the categories given in Appendix A: