



AMENDMENT NO. 1 DECEMBER 1984

TO

**IS : 9893-1981 SPECIFICATION FOR
PRECAST CONCRETE LINTELS AND SILLS**

Alterations

(*Page 3, clause 0.3*) — Substitute the following for the existing clause:

'0.3 The precast lintels and sills covered in this standard are intended primarily for use in buildings.'

(*Page 5, clause 2.1.4*) — Substitute the following for the existing matter:

'A 16 mm wide throating as shown in Fig. 4 shall be provided along the outer edge of the soffit of external lintels.'

(*Page 12, clause 6.1*) — Substitute the following for the existing clause:

'6.1 Precast concrete lintels and sills shall be lifted by means of a cradle made up of stout timber planks, well-battened together on the underside or any other suitable means not likely to damage the precast units, care being taken to prevent the lintels and sills from being subjected to impact.'

Addendum

(*Page 12, clause 6.2*) — Add the following sentence at the end:

'Flush type hooks or inserts may also be used for lifting the lintels and sills.'

(BDC 2)