

AMENDMENT NO. 1 NOVEMBER 1987

TO

IS:9900(Part 1)–1981 SPECIFICATION FOR
HIGH PRESSURE MERCURY VAPOUR LAMPS

PART 1 REQUIREMENTS AND TESTS

(Page 3, clause 0.7) - Substitute the following
for the existing clause:

'0.7 The lamps covered by this standard can be
operated in a voltage range of 200 to 250 V.'

(Page 7, clause 6.1) - Add the following in the
end:

'(e) The rated lumen output.

Note - The manufacturer may declare a higher
value of rated lumen output than the minimum
specified in the standard. Due to limitation
of space on lamps this information may,
however, be marked on the carton only.'

(ETDC 23)