

AMENDMENT NO. 2 JUNE 1988
TO
IS : 9900 (Part 1)-1981 SPECIFICATION FOR
HIGH PRESSURE MERCURY VAPOUR LAMPS

PART 1 REQUIREMENTS AND TESTS

(Page 5, clause 2.13.2) — Add the following new clause after 2.13.2:

'2.13.3 *Life Test Quantity (LTQ)* — The number of lamps selected for the purpose of determining the acceptability of a batch as to life performance.'

(Page 7, clause 5.3) — Add the following new clause and renumber the existing clause 5.4 as 5.5 :

'5.4 *Life Test Quantity (LTQ)* — From the lamps which have passed rating test, they shall be selected at random a LTQ as follows :

- a) For lamps up to and including 400 W 10
- b) For lamps above 400 W 5'

(Page 9, clause 8) — Substitute the following for the existing clause :

'8. REQUIREMENTS AND CONDITIONS OF TEST FOR LIFE PERFORMANCE

8.1 After 5 000 hours operation, including the ageing period of 100 hours, the lumen maintenance shall not be less than the value indicated below :

- a) For lamps up to and including 400 watts 80 percent
- b) For lamps above 400 watts 75 percent'

(Page 9, clause 9.3.2) — Add the following new clause after 9.3.2:

'9.3.3 *Lumen Maintenance* — A batch shall be considered to comply with the requirements of life if the total number of lamps having lives shorter than 5 000 hours, together with those failing to meet the requirements of lumen maintenance given in 8 does not exceed the qualifying limits given below :

<i>Life Test Quantity</i>	<i>Qualifying Limit</i>
10	2
5	1'

(ETDC 23)