

AMENDMENT NO. 1 JULY 2026
TO
IS 9968 (PART 1) : 2025 ELASTOMER INSULATED CABLES —
SPECIFICATION
PART 1 FOR WORKING VOLTAGES UP TO AND INCLUDING 1 100 VOLTS
(Second Revision)

(Page 2, clause 9.1.1) — Substitute the following for existing:

‘The sheath shall consist of elastomeric compound complying with the requirements of Type SE 1 or SE 2 of IS 6380.’

(Page 2, clause 9.1.2) — Substitute the following for existing:

‘The sheath shall consist of elastomeric compound complying with the requirements of Type SE 2 of IS 6380.’

(Page 3, clause 9.2.2) — Substitute the following for existing:

‘The sheath shall consist of elastomeric compound complying with the requirements of Type SE 4 of IS 6380.’

[Page 3, clause 11.1, SI No. (iv)] — Delete the row.

[Page 3, clause 11.1, SI No. (v)] — Delete the row.

(Page 3, clause 11.2) — Substitute the following for existing:

‘For silicon rubber insulated cables and for all other flexible cable or cords — copper conductor of Class 5 of IS 8130 shall be used.’

(Page 3, clause 13.2) — Substitute the following for existing:

‘The average thickness of the insulation shall be not less than the nominal value (t_i) specified in respective tables.’

[Page 4, clause 14.2, SI No. (iii), col (5)] — Substitute ‘black’ for ‘yellow’.

(Page 4, clause 15, sentence 2) — Substitute the following for existing:

‘The tape, when provided, shall be applied with an overlap of minimum 15 percent of tape width.’

(Page 4, clause 19) — Substitute the following for the existing:

‘The proofed tape or glass tape or PETP tape or plastic tape or any other suitable tape over laid up cores shall be applied as required in the respective Table 2, 5, 6, 9 and Table 10 with an overlap of minimum 15 percent of tape width.’

(Page 4, clause 20.1, sentence 2) — Substitute ‘The material of the sheath shall be as specified in the respective Table 2, 3, 5, 6 and Table 10’ for the existing.

[Page 5, clause 22.1, SI No. (ii) (e), col (3)] — Substitute ‘21’ for ‘22’.

[Page 5, clause 22.1, SI No. (ii) (g), col (2)] — Substitute the following for existing:

‘Hot set test for insulation and sheath (not applicable for IE 5 and SE5);’

[Page 5, clause 22.1, SI No. (iii) (f), col (3)] — Substitute ‘21’ for ‘22’.

Price Group 1

Amendment No. 1 to IS 9968 (PART 1) : 2025

[Page 8, Table 1, Sl No. (a)] — Substitute the following for the existing:

‘Plain or Tinned annealed copper or aluminum conductor (see 4, 11.1);’

(Page 10, Table 3, col (4) and col (5), heading) — Substitute the following for the existing:

Nominal Thickness of Sheath (ts)	
Flat Twin-Core (mm)	Flat Three-Core (mm)

[Page 11, Table 4, Sl No. (a)] — Substitute the following for the existing:

‘Plain or Tinned annealed copper or aluminum conductor for cables for fixed wiring and tinned annealed copper for flexible cables and cords (see 4, 11.1 and 11.2);’.

[Page 11, Table 4, Sl No. (d) under 2, 3 and 4-Core Cables] — Insert ‘e) Optional Binder tape (see 6);’ and renumber subsequent Sl Nos.

[Page 12, Sl No. (c)] — Insert ‘3) Silicone rubber elastomeric (see 5.3)’.

[Page 12, Sl No. (e)] — Substitute ‘HOFR’ for ‘HFFR’.

[Page 12, Sl No. (g)] — Substitute the following for the existing:

‘Heavy duty sheath (9.1.2) in case of general purpose rubber insulation, heavy duty HOFR sheath (9.2.2) in case of heat resisting rubber and silicone rubber sheath (9.3) in case of silicone rubber insulation.’

[Page 13, Sl No. (g)] — Substitute the following for the existing:

‘General service sheath (see 9.1.1) in case of general service insulation and heat resisting sheath (see 9.2.1) in case of heat resisting insulation and silicone rubber sheath (see 9.3) in case of silicone rubber insulation.’

(Page 14, Table 7, col (3), heading) — Insert (ti) after Insulation.

(Page 15, Table 9, col (3), heading) — Insert (ti) after Insulation.