

AMENDMENT NO. 4 MARCH 2007
TO
IS 9974 (PART 1) : 1981 SPECIFICATION FOR HIGH
PRESSURE SODIUM VAPOUR LAMPS

PART 1 GENERAL REQUIREMENTS AND TESTS

(Page 7, clause 7.4.1) — Insert the following new subclause after 7.4.1:

‘7.4.2 Rated luminous flux of the lamps shall not be less than the value shown on the relevant lamp data sheet of Part 2 of this standard. The initial luminous flux of individual lamp shall not be less than ninetytwo percent of the rated luminous flux.’