

AMENDMENT NO. 1 JANUARY 2000
TO
IS 3550 : 1965 METHODS OF TEST FOR ROUTINE
CONTROL FOR WATER USED IN INDUSTRY

(*Page 10, clause 9.1.3*) — Insert the following at the end of the clause:

'NOTE — The multiplication factor 0.667 may vary from 0.550 to 0.900 depending upon the nature of sample. Therefore, it is advisable to determine the factor for a particular sample, using gravimetric method [*see* IS 3025 (Part 16) Methods of sampling and test (physical and chemical) for water and waste water : Part 16 Filterable residue (total dissolved solids) (*first revision*).]'

(*Page 13, clause 11.2, Note 2, line 3*) — Insert the following after the words 'buffer solution':

'(pH to be maintained between 10.0 to 10.1)'

(CHD 12)