

AMENDMENT NO. 1 MAY 2005
TO
IS 3595 : 2002 CODE OF PRACTICE FOR
FIRE SAFETY OF INDUSTRIAL BUILDINGS : COAL
PULVERIZERS AND ASSOCIATED EQUIPMENTS
(Second Revision)

(*Page 12, clause 11.5*) — Substitute 'A B C Class dry powder extinguisher' for 'fixed halon fire extinguishing systems'.

(CED 36)

Reprography Unit, BIS, New Delhi, India