

**AMENDMENT NO. 2 JULY 2005
TO
IS 3597 : 1998 CONCRETE PIPES — METHODS
OF TEST**

(Second Revision)

[Page 4, clause 8.1 (see also Amendment No.1)] — Substitute the following for the existing heading:

'8.1 Prestressed Concrete Pipes, Bar/Wire Wrapped Steel Cylinder Pipes with Mortar Lining and Coating and Precast Concrete Pipes'

[Page 4, clause 8.1, third sentence (see also Amendment No. 1)] — Substitute the following for the existing:

'For Prestressed Concrete Pipes and Bar/Wires Wrapped Steel Cylinder Pipes with Mortar Lining and Coating, the test shall be conducted at three places on coating and for Precast concrete pipes at two places simultaneously, immediately after curing is completed (see Fig. 4).'

[Page 4, clause 8.1.3, third sentence (see also Amendment No. 1)] — Substitute the following for the existing:

'The average of tests conducted at three places for Prestressed Concrete Pipes and Bar/Wire Wrapped Steel Cylinder Pipes with Mortar Lining and Coating and the average of tests conducted at two places for Precast Concrete Pipes shall be expressed in cm^3 as final permeability.'

[Page 5, Fig. 4 (see also Amendment No.1)] — Substitute 'N.B. 6.25 ± 0.06 mm or O.D. 8 mm with wall thickness of 1.00 ± 0.25 mm' for 'N.B. 6.3', as dimension of glass tube.

(CED 53)