

AMENDMENT NO. 1 MAY 1993
TO
IS 5613 (Part 1 / Sec 1) : 1985 CODE OF PRACTICE
FOR DESIGN, INSTALLATION AND MAINTENANCE
OF OVERHEAD POWER LINES

PART 1 LINES UP TO AND INCLUDING 11 kV

Section 1 Design

(First Revision)

(Page 9, Table 1, Title) — Substitute '6 percent voltage regulation' for '5 percent voltage regulation'.

(Page 10, Table 2, Title) — Substitute '+6 percent to -9 percent voltage regulation' for '12.5 percent voltage regulation'.

(ET 37)