

**AMENDMENT NO.1 SEPTEMBER 2007
TO
IS 5613 (PART 2/SEC 2) : 1985 CODE OF
PRACTICE FOR DESIGN, INSTALLATION
AND MAINTENANCE OF OVERHEAD
POWER LINES**

**PART 2 LINES ABOVE 11 kV AND UP TO AND
INCLUDING 220 kV**

Section 2 Installation and Maintenance

(Page 6, clause 5.3.2, informal table) --- Add the following note:

'NOTE - Lower values of Right-of-Way may be adopted by power utilities by use of V-strings or adopting smaller spans in the forest areas, based on the Line Clearance (Right-of-Way) Requirement in accordance with Fig. 1'