

AMENDMENT NO. 1 FEBRUARY 2001
TO
IS 5714 : 1981 SPECIFICATION FOR HYDRANT
STAND-PIPE FOR FIRE FIGHTING
(First Revision)

(*Page 4, clause 2.1*) — Insert following new matter after 'd)':

'e) Chain(s) Galvanized Steel'.

(*Page 4, clause 3.6*) — Insert the following matter:

Chain shall be of Galvanized steel wire conforming to IS 280.'

(*Page 5, Fig. 1*) — Insert the following footnote IV:

'iv) For double outlet stand pipe, handle size shall be 100 mm with a thickness of 5 mm.'

(*Page 7, clause 4.3*) — Insert new clause:

'Blank cap of ABS plastics shall be as given in Fig. 3.'

(*Page 7, clause 6.2*) — Insert new clause:

'6.2 Flow Test — Water shall be discharged through the assembly and its flow shall be measured using a flow meter or V-notch. The flow shall not be less than 900 litres per minute at 0.7 MN/m^2 (7 kgf/cm^2) from each outlet. It shall be a type test.'

(CED 22)