

AMENDMENT NO. 1 APRIL 1985

TO

IS:5831 -1984 SPECIFICATION FOR PVC INSULATION AND SHEATH OF ELECTRIC CABLES

(First Revision)

[Page 5, Table 1, *Sl* No, (v), *item* (a)] - Insert the following after this *item*:

'(1)	(2)	(3)	(4)	(5)	(6)	(7)
b)	Loss of mass, <i>Max</i>	mg/cm ²	2	-	-	'

[Page 6, Table 1, *Sl* No, (vi), *item* (b), first case, *col*(6)] - Substitute '4' for '-'.

[Page 7, Table 1, *Sl* No. (xv)]:

- a) - Substitute 'tolerance' for 'toterance'.
- b) - Substitute 'absorbed' for 'absorted'.

[Page 8, Table 2, *Sl* No.(iv), *item*(a), *col* (5)] - Substitute '80' for '30'.

(Page 11, clause A-1, *line* 1)- Substitute 'cut' for 'out'.

(Page 11, clause B-1.1, '*line* 1)- Substitute 'Glass' for 'Class'.

(ETDC 59)