

AMENDMENT NO. 1 SEPTEMBER 1993
TO
IS 5834 (Part 3) : 1981 SPECIFICATION FOR
ELECTRICAL TIMER RELAYS FOR INDUSTRIAL
PURPOSES

PART 3 ELECTRONIC

(Page 4, clause 2.0) — Substitute 'IS 1885 (Part 9) : 1986' for 'IS 1885 (Part IX) -1966'.

(Page 4, foot-note) — Substitute 'Electrotechnical vocabulary: Part 9 Electrical relays (first revision)' for 'Electrotechnical vocabulary: Part IX Electrical relays'.

(Page 5, clause 2.17, seventh line) — Replace as follows:

$$\text{Repeat accuracy} = \frac{(T_1 - T_2)}{2 \frac{T^1}{n}} \times 100 \text{ percent}$$

(Page 8, clause 5.3) — Replace as follows:

'The percentage change in the set operating time under the following conditions shall not exceed the limits declared by the manufacturer:

- | | | |
|----|-------------------------------|---|
| a) | Change in supply voltage | -15 percent + 10 percent of rated voltage |
| b) | Change in supply frequency | ±5 percent of rated frequency |
| c) | Change in ambient temperature | -5°C to 45°C |

[Page 8, clause 7.1 (a), fifth line] — Delete '†' mark.

(Page 8, foot-note marked with '†') — Delete.

(Page 9, clause 7.2) — Substitute the following for the existing:

'7.2 The relay may also be marked with Standard Mark.