

AMENDMENT NO. 2 APRIL 1994
TO
IS 5834 (Part 3) : 1981 SPECIFICATION FOR
ELECTRICAL TIMBER RELAYS FOR INDUSTRIAL
PURPOSES

PART 3 ELECTRONIC

[Page 5, clause 2.17, seventh line (see also Amendment No. 1)] —
Replace 'Repeat accuracy' equation as follows:

$$\text{Repeat accuracy} = \frac{T_1 - T_2}{2 \sum \frac{T}{n}}$$

in place of

$$\text{Repeat accuracy} = \frac{T_1 - T_2}{2 \frac{T^1}{n}}$$

(Page 8, clause 5.3) — Replace as follows:

'The percentage change in the set operating time under the following conditions shall not exceed the limits declared by the manufacturer:

- a) Change in supply voltage - 15 percent to +10 percent of rated voltage
in place of

Change in supply voltage - 15 percent to +10 percent of rated voltage

(Page 9, clause 7.2) — Substitute the following for the existing:

7.2 BIS Certification Marking

7.2.1 The relay may also be marked with Standard Mark.

The use of the Standard Mark is governed by the provisions of the Bureau of Indian Standards Act, 1986 and the Rules and Regulations made thereunder. The details of conditions under which the licence for the use of Standard Mark may be granted to manufacturers or producers may be obtained from the Bureau of Indian Standards.'

(ETD 35)

Reprography Unit, BIS, New Delhi, India