

AMENDMENT NO. 1 DECEMBER 2000
TO
IS 8309 : 1993 COMPRESSION TYPE TUBULAR
TERMINAL ENDS FOR ALUMINIUM CONDUCTORS OF
INSULATED CABLES — SPECIFICATION
(*First Revision*)

(*Page 3, Table 1, col 6, Row 10, Designation CAA-50*) — Substitute
'18.0-18.6' for '8.0-18.6'.

(*Page 3, Table 1, col 6, Row 13, Designation CAA-120*) — Substitute
'27.7-28.3' for '27.7-38.3'.

(ETD 9)

Printed at Simco Printing Press, Delhi