

**AMENDMENT NO. 1 NOVEMBER 2011
TO
IS 4020 (PART 3) : 1998 DOOR SHUTTERS —
METHODS OF TESTS**

PART 3 MEASUREMENT OF GENERAL FLATNESS

(Third Revision)

(Page 3, clause 2.1, first sentence) — Substitute the following for the existing:

‘The door shutter is held freely in a vertical plane or mounted vertically with its long edge horizontal.’

(Page 3, clause 2.1, fourth & fifth sentences) — Substitute the following for the existing:

‘The measuring points shall be 20 ± 5 mm from the edges. It shall be measured to an accuracy of 0.1 mm.’

(Page 3, clause 2.2) — Substitute the following for the existing:

‘The door shutter is held as given in 2.1. Measurement(s) of warping and cupping on one of the faces of the door shutters is measured with respect to a straight edge held parallel to each edge and located not more than 20 mm from the edge. The distance of the face from the straight edge is measured (*see* Fig. 2). The deviation shall be measured to an accuracy of 0.1 mm.’