

AMENDMENT NO. 1 NOVEMBER 2011
TO
IS 4020 (PART 4) : 1998 DOOR SHUTTERS —
METHODS OF TESTS

PART 4 LOCAL PLANENESS TEST

(Third Revision)

(Page 4, clause 2, third and fourth sentences) — Substitute the following for the existing:

‘A suitable measuring device suitably fixed at the centre of a straight edge of 200 mm length shall be placed on the different squares on the face of the door shutter. The depth at each point shall be measured to an accuracy of 0.05 mm. The procedure shall be repeated for the other face.’

(CED11)