

AMENDMENT NO. 1 JUNE 1932

TO

IS:3347(Part I/Sec 2)-1979 DIMENSIONS FOR PORCELAIN
TRANSFORMER BUSHINGS FOR USE IN NORMAL
AND LIGHTLY POLLUTED ATMOSPHERES

PART I UP TO AND INCLUDING 1 kV

Section 2 Metal Parts

(Piret Revision)

Alteration

(Page 6, clause 2.1, informal table, last entry) -
Substitute the following for the existing:

<i>'Metal Part or Accessory</i>	<i>For Bushing with Copper Stem</i>	<i>For Bushing with Aluminium Stem</i>
Connecting lug	For 1 000 and 2 000 A brass conforming to Grade 3 of IS:292-1961** or to IS:3488- 1966† For 3 150 A copper chromium alloy	Aluminium alloy conforming to A-6-M designation of IS:617-1975* or any other suitable aluminium alloy to be agreed between the manufacturer and the purchaser.'

Addendum

(Page 6, foot-note with '1' mark) - Add the
following new foot-note after '1' mark:

'**Specification for brass ingots and castings
(revised):'

(ETDC 3)