

AMENDMENT NO. 3 MARCH 1989
TO
IS : 3347 (Part 1/Sec 2) - 1979 DIMENSIONS FOR
PORCELAIN TRANSFORMER BUSHINGS FOR
USE IN NORMAL AND LIGHTLY POLLUTED
ATMOSPHERES

PART 1 UP TO AND INCLUDING 1 kV
Section 2 Metal Parts
(First Revision)

(First cover, pages 1 and 3, title) — Substitute the following for the
existing title:

Indian Standard
DIMENSIONS FOR PORCELAIN TRANSFORMER
BUSHINGS FOR USE IN LIGHTLY POLLUTED
ATMOSPHERES

PART 1 UP TO AND INCLUDING 1 kV
Section 2 Metal Parts
(First Revision)

(Page 3, clause 0.3, first and second lines)

(Page 5, clause 1.1, third line)

} Delete the words 'normal
and'.

(Page 15, Fig. 12) — Substitute the figure given on page 2 for the
existing figure.




FIG. 12 GASKET (R AND X TYPE)

All dimensions in millimetres.

TYPE	RATING kV/A	BUSHING WITH ALUMINIUM STEM			BUSHING WITH COPPER STEM		
		d_{26}	d_{27}	T	d_{26}	d_{27}	T
R	1/250	45	70	3	28	50	3
R	1/630	56	90	3	40	70	3
R	1/1 000	70	104	3	45	70	3
R	1/2 000	90	125	3	70	104	3
R	1/3 150	—	—	—	90	125	3
X	1/250	40	70	3	25	50	3
X	1/630	45	70	3	45	70	3
X	1/1 000	63	90	3	56	90	3
X	1/2 000	80	110	3	70	104	3
X	1/3 150	—	—	—	90	125	3

(ETDC 3)