

AMENDMENT NO. 1 JUNE 1982

TO

IS:3347 (Part II/Sec 2)-1979 DIMENSIONS FOR PORCELAIN
TRANSFORMER BUSHINGS FOR USE IN NORMAL
AND LIGHTLY POLLUTED ATMOSPHERES

PART II 3.5 kV BUSHINGS

Section 2 Metal Parts

(First Revision)

Alteration

(Page 6, clause 2.1, informal table, last enegy)
Substitute the following for the existing entry:

<i>Metal Part of Accessory</i>	<i>For Bushing with Copper Stem</i>	<i>For Bushing with Aluminium Stem</i>
Connecting lug	For 1000 and 2000 A brass conforming to Grade 3 of IS:292-1961** or to IS:3488-1966† For 3 150 A copper chromium alloy	Aluminium alloy conforming to A-6-M desimatic of IS:617-1975* or any other suitable aluminium alloy to be agreed between the manufacturing and the purches

Addendum

*(Page 6, foot-note with '§' mark) - Add the
following new foot-note after '§'mark:*

****Specification for brass ingots and castings (*revise*)**

(ETDC 3)