

**AMENDMENT NO. 3   APRIL 1994**  
**TO**  
**IS 3347 (Part 4/Sec 2) : 1982   DIMENSIONS FOR**  
**PORCELAIN TRANSFORMER BUSHINGS FOR USE IN**  
**LIGHTLY POLLUTED ATMOSPHERES**  
**PART 4   24 kV BUSHINGS**  
**Section 2 Metal Parts**  
**( First Revision )**

( Page 11. Fig. 1 ) — Substitute ' $R\ 2.5 \pm 0.1$ ' for ' $R\ 3.5 \pm 0.1$ ' for dimensions of locking pins.

( ETD 06 )

---

Reprography Unit, BIS, New Delhi, India