

AMENDMENT NO. 1 JUNE 2024
TO
IS 3370 (PART 1) : 2021 CONCRETE STRUCTURES FOR RETAINING
AQUEOUS LIQUIDS — CODE OF PRACTICE
PART 1 GENERAL REQUIREMENTS
(Second Revision)

(Page 1, clause 3.7, line 4) — Delete 'or up to the overflow level'.

(Page 2, clause 3.11, line 4) — Substitute 'on' for 'between'.

(Page 2, clause 3.14, line 1) — Delete 'member'.

[Page 9, clause 11.2 (b), para 5, line 3] — Substitute '30' for '15'.

[Page 9, clause 11.2 (b), para 5, line 5] — Substitute '300' for '250'.

[Page 9, clause 11.2 (b), para 5, line 5] — Insert the following at the end:

‘Where, shear key and water-bar both are given at a section, the thickness should be minimum 400 mm.’

(Page 12, clause 11.5.1.2, line 15) — Substitute ‘height’ for ‘heigt’.

(Page 13, clause 11.5.4, para 1, line 4) — Delete ‘directly’.

(Page 13, clause 11.5.4, para 2, line 4) — Substitute ‘bay’ for ‘bays’ and ‘area’ for ‘areas’.

(Page 16, clause 12.2, para 2, line 13) — Substitute ‘water-bar’ for ‘water base’.

(CED 02)

Price Group 1

Publication, BIS, New Delhi