

AMENDMENT NO. 2 SEPTEMBER 1977

TO

**IS:7634(Part I)-1975 CODE OF PRACTICE FOR
PLASTICS PIPE WORK FOR POTABLE
WATER SUPPLIES**

**PART I CHOICE OF MATERIALS AND
GENERAL RECOMMENDATIONS**

Alterations

(Page 4, clause 1.1, line 2) - Delete the words 'up to 37°C'.

(Page 4, clause 3.1.3) - Substitute the following for the existing clause:

"3.1.3 The tensile strength of plastics decreases with increase in temperature and impact strength tends to decrease with decrease in temperature. Thermoplastics in general deform under prolonged loading however small. Such a property of thermoplastics is called, 'cold flow'. Normally to prevent failure due to cold flow, it is advisable not to allow stresses in the pipe due to cold bending particularly when the radius is too short [see (Part II) of this code]. Therefore permanent thermoformed bends conforming to relevant Indian Standards on plastics fittings for potable water supplies are recommended to be used."

(Page 4, note under clause 3.1.3) - Delete.

(Page 6, clause 3.3, line 4) - Substitute 'pipe' for 'pump'.

(Page 6, clause 3.4.1, line 1) - Substitute 'plastics' for 'plastic'.

(Page 7, clause 5.1, line 1) - Substitute 'plastics' for 'plastic'.

(Page 8, note under clause 7.4, line 9) - Substitute 'steady' for 'study'.

(BDC 3)