

AMENDMENT NO. 2 JUNE 2015
TO
IS/ISO 7396-1 : 2007 MEDICAL GAS PIPELINE SYSTEMS
PART 1 PIPELINE SYSTEMS FOR COMPRESSED MEDICAL GASES
AND VACUUM

[Page 13, *clause 5.5.1.3*] — Substitute the following for the existing clause:

‘**5.5.1.3** Medical air and air for driving surgical tools shall not be provided for applications such as general workshop use, motor repair workshop use, spray painting, tyre inflation, reservoirs for pressurization of hydraulic fluids, sterilizing systems and/or pneumatic control of air conditioning. Medical air and air for driving surgical tools shall also not be provided for any other application which can impose unforeseen demands and could compromise the availability and/or quality of air for the intended purposes.’