

**AMENDMENT NO. 1 APRIL 2001
TO
IS 7809 (PART 2) : 1977 SPECIFICATION FOR
PRESSURE SENSITIVE ADHESIVE TAPES FOR
ELECTRICAL PURPOSES
PART 2 METHODS OF TEST**

[*Page 8, clause 6.5(a)*]—Substitute the following for the existing matter.

"**a**) The product is described as 'Flame-Retardant' under the terms of this standard if at least four of the five specimens retard flame and fire gets extinguished before the 50 mm mark is reached."

[*Page 8, clause 6.5(b)*] — Delete and renumber subsequent items accordingly.

(ET 02)

Reprography Unit, BIS, New Delhi, India