

AMENDMENT NO. 2 FEBRUARY 1983

TO

IS : 7935-1975 SPECIFICATION FOR INSULATOR FITTINGS FOR
OVERHEAD POWER LINES WITH A NOMINAL VOLTAGE
UP TO AND INCLUDING 1 000 V

Alterations

(Page 10, clause 4.8) - Substitute the following
for the existing clause:

4.8 Mechanical Strength Test - Shank of the insulator pin shall be rigidly attached to the testing machine. A rigid metal extension piece shall be attached directly to the head of the pin. A load shall be applied to the extension piece 10 mm above the top of the pin. The load applied, at right angle to the axis of the insulator pin, shall be increased to the specified minimum failing load at a steady rate. The permanent deformation measured at the top of the pin head after the load has been released, shall not exceed 20 percent of the distance of this point from the support.

The minimum failing load of the insulator pin shall be as follows:

<i>Type</i>	<i>Minimum Failing Load</i>
Fabricated (Fig. 1)	2 kN
Forged Pin (Fig. 2)	2 kN
NOTE - 1N = 0.101922 kgf.'	

(Page 10, foot-note with '‡' mark) - Delete.

(ETDC 3)