

AMENDMENT NO. 3 NOVEMBER 1988
TO
IS : 7935 - 1975 SPECIFICATION FOR INSULATOR
FITTINGS FOR OVERHEAD POWER LINES WITH
A NOMINAL VOLTAGE UP TO AND INCLUDING
1 000 V

(*Page 5, clause 3.1.3*) — Insert the following at the end of this clause;
'The thickness of the hexagon nuts shall be in accordance with IS - 1363
(Part 3) - 1984*. The screw threads on the shank and the nut shall be
as specified in IS : 4218 (Part 6) - 1978† '

(*Page 7, Fig 3*) — Delete the dimension '12' shown as the thickness
of the nut of the shackle pin.

*Hexagon head bolts, screws and nuts of product grade C: Part 3 Hexagon nuts
(size range M 5 to M 36) (*second revision*)

†ISO metric screw threads' Part 6 Limits of sizes for commercial bolts and nuts
(diameter range 1 to 52 mm) (*first revision*).

(ETDC 3)

Reprography Unit, BIS, New Delhi, India