

AMENDMENT NO. 1 MAY 1981**TO****IS : 8009 (Part I)-1976 CODE OF PRACTICE FOR
CALCULATION OF SETTLEMENTS
OF FOUNDATIONS****PART I SHALLOW FOUNDATIONS SUBJECTED TO
SYMMETRICAL STATIC VERTICAL LOADS****Corrigenda**

(Page 6, clause 3.0, line 5) — Substitute 'C' for 'c'.

(Page 15, clause 9.1.2, equation 2) — Substitute 'C' for 'c'.

(Page 22, Fig. 12, legend) — Substitute $\sqrt{\frac{LB}{D}}$ for $\sqrt{\frac{LB}{D}}$

(Page 32, clause B-3.2, last line) — Substitute 'η' for 'ηz'.

Alterations

(Page 7, clause 3.0, symbol S_1) — Delete along with its explanation.

(Page 12, clause 7.1, line 2) — Substitute 'IS : 1892-1979*' for 'IS : 1892-1962* '.

(Page 12, foot-note with '*' mark) — Substitute the following for the existing foot-note:

'*Code of practice for sub-surface investigations for foundation (first revision).'

(Page 15, clause 9.1.2, lines 2 and 3) — Substitute 'IS : 4968 (Part III)-1977*' for 'IS : 4968 (Part III)-1971* '.

(Page 15, foot-note with '*' mark) — Substitute the following for the existing foot-note:

'*Method for subsurface sounding for soils : Part III Static cones penetration test (first revision).'

(Page 16, clause 9.1.3) — Substitute the following for the existing clause:

'9.1.3 Method Based on Plate Load Test — Plate load test should be performed at the proposed foundation level and the settlement of a square

plate under the design intensity of loading on the foundation estimated (see IS: 1888-1971*). Then the total settlement of the proposed foundation is given by:

$$S_f = S_p \left[\frac{B (B_p + 30)}{B_p (B + 30)} \right]^2$$

NOTE — If the water table is at shallow depths or if it is expected that the water table for the foundations will be different from what is obtained at the time of the field load test, then, the effect of water table on the bearing capacity of the foundations may be different from that for the load test. Therefore, the water table correction given in Fig. 9 may be suitably adopted for the load test and the foundations'.

(Page 16, clause 9.1.4, last sentence) — Substitute the following for the existing sentence:

‘If the water table is at a shallow depth, the settlement read from Fig. 9 shall be divided, by the correction factor W' read from the inset in the same figure.’

(Page 16, clause 9.2.2.1) — Substitute the following for the existing clause:

‘9.2.2.1 For situations shown in Fig. 2 it may be assumed that:

$$S_i = 0, \text{ and}$$

$$S_c = S_{\text{oad}}$$

NOTE — To be exact, the settlement of the sand layers may also have to be added to the computed value of S_f . The designer has to use his discretion whether to add the settlement due to the sand layers or not.

The details of the computations of S_{oad} depends upon the preloading conditions. The details are given in 9.2.2.2 to 9.2.2.4.’

Addendum

(Page 7, clause 3.0) — Add the following symbols at appropriate places:

‘ S_p = Settlement of test plate under a given load intensity per unit area, cm

B_p = Size of test plate, cm’