

AMENDMENT NO. 1 NOVEMBER 2008
TO
IS 8090 : 1976 SPECIFICATION FOR COUPLINGS,
BRANCH PIPES, NOZZLE USED IN HOSE REEL
TUBING FOR FIRE FIGHTING

(Page 4, clause 2.1.3) — Substitute the following for the existing:

‘Leaded Tin Bronze — Leaded tin bronze used for coupling, nozzle and branch pipe shall conform to grade 2 of IS 318.’

(Page 5, clause 6.1) — Substitute the following for the existing:

‘6.1 The shape and dimensions of the branch pipe having shut off provision shall conform to Fig. 2.’

(Page 6, clause 6.2.3) — Add the following new clause:

‘6.2.4 The branch pipe shall have mechanism to turn off and on the discharge using a quarter turn operation. During discharge water shall not leak from the shut off. It shall be possible to shut off and open the branch pipe as and when desired by the user.’