

AMENDMENT NO. 1 JULY 2015
TO
IS 8130 : 2013 CONDUCTORS FOR INSULATED
ELECTRIC CABLES AND FLEXIBLE CORDS —
SPECIFICATION

(Second Revision)

(Page 2, clause 6.1.3) — Substitute ‘1.5 mm² up to and including 35 mm²,
for ‘10 mm² up to and including 35 mm²’.

[Page 3, clause 7.2.1 (a) and (b)] — Substitute ‘4.1’ for ‘3.1’.

(Page 4, Table 1, col 5) — Substitute the following for the existing, against
respective SI Nos.

SI No.	Aluminium Conductors Circular or Shaped Ω/km
(1)	(5)
iv)	18.1
v)	12.1
vi)	7.41
vii)	4.61
viii)	3.08

(Page 4, Table 1, footnote²) — Substitute ‘1.5 mm² up to and including
35 mm², for ‘10 mm² up to and including 35 mm²’.