

AMENDMENT NO. 2 NOVEMBER 2025
TO
IS 8148 : 2018 DUCTED AND PACKAGE AIR-CONDITIONERS —
SPECIFICATION
(Second Revision)

[Page 3, clause **4.11**, para 2 (see also Amendment No. 1)] — Substitute the following for the existing:

‘The filter used on the evaporator coil of the unit shall have a maximum 70 percent open area when measured in an area of 1 cm². The measurement shall be made by measuring the wire diameter. Count the number of wires in 1 cm² to calculate closed area, deduct overlap area and calculate the total closed area.

Actual open area percent = (Total area – Closed area)/Total area × 100. A specimen of the cut piece removed from the filter for the purpose of measurement is shown below for guidance.’

