

AMENDMENT NO. 1 MARCH 2002
TO
IS 6784 : 1996 METHODS FOR PERFORMANCE
TESTING OF WATER METERS (DOMESTIC TYPE)
(Second Revision)

(*Page 3, clause 6.1, formula*) — Substitute the following for the existing formula:

$$\text{Percent error} = \frac{V_i - V_c}{V_c} \times 100$$

where

V_c = value accepted as true of the volume passed, and

V_i = volume indicated by the water meter at the time of measurement
of the same volume both expressed in the same units.

(*Page 3, clause 6.2.2.2, last sentence*) — Delete.

(CED 3)