

AMENDMENT NO. 3 JULY 1988

TO

**IS:6848-1979 SPECIFICATION FOR LEAD-ACID
BATTERIES FOR TRAIN LIGHTING AND
AIRCONDITIONING SERVICES**

(First Revision)

(Page 7, clause 3.3.4) - Add the following at the end:

'The vent plug and float guide dia for train lighting cells shall be 27 mm with pitch thread of 3 mm as per IS:4218-1976*. The central hole in float guide and vent plug shall be of 7 mm dia.'

(Page 10, clause 3.4.2) - Substitute the following for the existing clause:

'3.4.2 The height of electrolyte above the top of the separators in fully topped up conditions shall not be less than 40 mm.'

(Page 17, clause 5.12) - Substitute the following for the existing clause:

'5.12 Vibration Test - The test shall be performed in accordance with IS:2106(Part 16)-1971[†]. The samples shall be first tested for capacity test as per 5.4, before putting into vibration test. The test consists in vibrating the batteries at a frequency of 16 Hz with a total displacement of 5 mm for a period of 2 hours. During vibration the batteries shall be discharged at the 10 hour rate.

*ISO Metric screw threads.

+Vibration test.

5.12.1 Requirements - There shall not be any sudden drop, either in the current or voltage values and there shall be no spillage of electrolyte during the test.

(ETDC 11)