

**AMENDMENT NO. 3 AUGUST 2007
TO
IS 11833 : 1986 SPECIFICATION FOR DRY POWDER
FIRE EXTINGUISHER FOR METAL FIRES**

(Page 5, clause 6) — Insert the following new subclause:

‘6.7 Braided rubber/plastic hose shall be having bursting pressure not less than 50 kg/cm²’.

(CED 22)